ASTA LICENCE

ASTA DIAMOND MARK

Licence No. **1598**

Organization: **Elins Switchboards Pvt. Ltd.**
No. 65A1, 3rd Cross, Bommasandra Industrial Area
Bengaluru-56099, Karnataka
India

Product: Busbar Trunking System

Designation: Cu Sandwich Busway

Characteristics: Rated insulation voltage (U_i) = 1000V
Rated current (I_n) = 800A to 2500A
Class F insulated copper busbars
in a powder coated galvanised steel enclosure
(See Endorsements for full designations and ratings)

Approval Standard: IEC 61439-6 Edition 1.0 2012-05

Issue Number: 1

Review Date: 31 August 2031

Factory Reference: ELININ.A1

R.W. Hayward	**Name**
	Signature
11 September 2026	**Date**

This Licence is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Licence. Only the Client is authorized to permit copying or distribution of this Licence and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.
Issued by Intertek Testing & Certification Ltd., Academy Place, 1-9 Brook Street, Brentwood CM14 5NQ, United Kingdom
a UKAS accredited certification body, No. 0010