ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: G106493887 **Certificate No:** ASTA-TYPE-0004256

Applicant: Elins Switchboards Pvt Ltd.
No. 65 A1, 3rd Cross, Bommasandra Industrial Area,
Bengaluru-560099, Karnataka, India.

Apparatus: A range of 630A to 7200A, single-stack to triple-stack, 1000V/1000V/12kV (U_e=U_n/U_i/U_{imp}), 50Hz, IP55, TPN with external earth, sandwich busbar trunking systems with Class F insulated bare copper busbars enclosed in a powder coated galvanized steel enclosure. Samples comprising of straight lengths along with fire barrier and jointed straight lengths.

Manufacturer: Elins Switchboards Pvt Ltd.
No. 65 A1, 3rd Cross, Bommasandra Industrial Area,
Bengaluru-560099, Karnataka, India.

Test Report No: YDY25/001149

Designation: **e**lins Busways - Copper Sandwich

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-6 Edition 1.0 2012-05

Verifications with reference to the tests listed in Annex D of IEC 61439-6 Edition 1.0 2012-05

14: Resistance to flame propagation

15: Fire resistance in building penetration

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.

UKAS PRODUCT CERTIFICATION
0010

C Diack-Evans
Certification Engineer

Sreekumar P
Certification Officer

Date
9th March 2026

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.
Issued by Intertek Testing & Certification Ltd., Academy Place, 1-9 Brook Street, Brentwood CM14 5NQ, United Kingdom
a UKAS accredited certification body, No. 0010