CENTRAL POWER RESEARCH INSTITUTE

CPRI

TEST REPORT

Test Report Number: CPRIBLREATD1819T0086 **Dated: 04.06.2018**

Name & Address of the Customer	:	M/s.Elins Switch Boards Pvt. Ltd. 65A-1, 3rd Cross, Bommasandra Industrial Area, Bangalore – 560099.
Name & Address of the Manufacturer	:	M/s.Elins Switch Boards Pvt. Ltd. 65A-1, 3rd Cross, Bommasandra Industrial Area, Bangalore – 560099.

Particulars of sample tested

Condition of the sample on Receipt	:	New
Type	:	Outdoor.
Designation	:	Low Voltage Modular Bolted Panel
Serial Number	:	LVIP65-080518
Number of samples tested	:	One only.
Date (s) of Test (s)	:	24.05.2018 & 25.05.2018
CPRI sample code no(s)	:	EATDIP1819S0040

Particulars of tests conducted

Test in accordance with Standard / specification	:	IP 65 Category 1 Test as per IEC 60529 Edition 2.2, 2013-08 Standard. Clause 13.4, 13.6 and 14.2.5.
Sampling Plan	:	Not applicable
Customer's requirement	:	1. IP 65 Category 1 Test as per IEC 60529 Edition 2.2, 2013-08 Standard. Clause 13.4, 13.6 and 14.2.5. 2. Visual observation for entry of dust (IP 6X) and water (IP X5)
Deviations if any	:	-Nil-

Name of the witnessing persons

Customer's representative	:	Mr. Virrendra Sahdev, Sr. Manager – Marketing.
Other than customer's representatives	:	None
Test subcontracted with address of the laboratory	:	None

Documents constituting this report (In words)

Number of sheets	:	Three only
Number of oscillograms	:	-Nil-
Number of graphs	:	-Nil-
Number of photos	:	-Nil-
Number of test circuit diagrams	:	-Nil-
Number of drawings	:	One Only. Drawing No. ESPL – IP65 - 0518 Sheet 1 of 1.

(D VENKATESH)
Test Engineer

(Dr. P. CHANDRA SEKHAR)
Head of Division
Approved by

ELECTRICAL APPLIANCES TECHNOLOGY DIVISION
CENTRAL POWER RESEARCH INSTITUTE
PROF. SIR C. V. RAMAN ROAD, SADASHIVANAGARA P.O.
BENGALURU – 560 080, INDIA